



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school district is following all recommended remediation to help reduce children's overall exposure to lead in drinking water.

**School Name:** Hilltop Elementary

**School Code:** 3165

**School District Name:** Highline

**Address:** 12250 24th Ave South, Seattle WA 98168

**County:** King

**Number of Samples Collected:** 68

**Date Collected:** 12/05/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	17137				<1	12/17/2018	7:28 AM, 06256
2.	17138	First Draw	Bubbler	Outside Gym	<1	12/17/2018	Left Hand Side
3.	17139	First Draw	Bubbler	Outside Gym	<1	12/17/2018	Right Hand Side
4.	17140	First Draw	Bubbler	Room 407	<1	12/17/2018	
5.	17141	First Draw	Tap	Room 407	1	12/17/2018	
6.	17142	First Draw	Bubbler	Room 408	<1	12/17/2018	
7.	17143	First Draw	Tap	Room 408	<1	12/17/2018	
8.	17144	First Draw	Bubbler	Room 409	<1	12/17/2018	
9.	17145	First Draw	Tap	Room 409	<1	12/17/2018	
10.	17146	First Draw	Bubbler	Room 410	<1	12/17/2018	
11.	17147	First Draw	Tap	Room 410	<1	12/17/2018	
12.	17148	First Draw	Tap	Staff Room	<1	12/17/2018	
13.	17149	First Draw	Bubbler	Room 411	1	12/17/2018	
14.	17150	First Draw	Tap	Room 411	<1	12/17/2018	
15.	17151	First Draw	Bubbler	Room 412	<1	12/17/2018	
16.	17152	First Draw	Tap	Room 412	<1	12/17/2018	
17.	17153	First Draw	Bubbler	Room 413	<1	12/17/2018	
18.	17154	First Draw	Tap	Room 413	1	12/17/2018	
19.	17155	First Draw	Bubbler	Room 414	<1	12/17/2018	
20.	17156	First Draw	Tap	Room 414	<1	12/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
21.	17157	First Draw	Bubbler	Room 419	<1	12/17/2018	Music Room
22.	17158	First Draw	Tap	Room 419	2	12/17/2018	Music Room
23.	17159	First Draw	Bubbler	Room 208	<1	12/17/2018	
24.	17160	First Draw	Tap	Room 208	<1	12/17/2018	
25.	17161	First Draw	Bubbler	Room 206	<1	12/17/2018	
26.	17162	First Draw	Tap	Room 206	<1	12/17/2018	
27.	17163	First Draw	Bubbler	Down the Hall from Room 206	1	12/17/2018	
28.	17164	First Draw	Bubbler	Room 204	<1	12/17/2018	
29.	17165	First Draw	Tap	Room 204	<1	12/17/2018	
30.	17166	First Draw	Bubbler	Room 202	<1	1/16/2019	
31.	17167	First Draw	Tap	Room 202	1	12/17/2018	
32.	17168	First Draw	Bubbler	Room 201	3	12/17/2018	
33.	17169	First Draw	Tap	Room 201	<1	12/17/2018	Used by staff member this morning
34.	17170	First Draw	Bubbler	Room 203	<1	12/17/2018	
35.	17171	First Draw	Tap	Room 203	2	12/17/2018	
36.	17172	First Draw	Bubbler	Room 205	<1	12/17/2018	
37.	17173	First Draw	Tap	Room 205	<1	12/17/2018	
38.	17174	First Draw	Bubbler	Room 207	1	12/17/2018	
39.	17175	First Draw	Tap	Room 207	1	12/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
40.	17176	First Draw	Bubbler	Room 110	2	12/17/2018	
41.	17177	First Draw	Tap	Room 110	1	12/17/2018	
42.	17178	First Draw	Bubbler	Room 109	7	1/16/2019	
43.	17179	First Draw	Tap	Room 109	3	1/16/2019	
44.	17180	First Draw	Bubbler	Room 108	1	1/16/2019	
45.	17181	First Draw	Tap	Room 108	<1	12/17/2018	
46.	17182	First Draw	Bubbler	Across from Room 108	2	12/17/2018	
47.	17183	First Draw	Bubbler	Room 107	6	1/16/2019	
48.	17184	First Draw	Tap	Room 107	1	1/16/2019	Used by staff member this morning
49.	17185	First Draw	Bubbler	Room 106	<1	12/17/2018	
50.	17186	First Draw	Tap	Room 106	1	12/17/2018	
51.	17187	First Draw	Bubbler	Room 105	<1	12/17/2018	
52.	17188	First Draw	Tap	Room 105	<1	12/17/2018	
53.	17189	First Draw	Bubbler	Room 104	1	12/17/2018	
54.	17190	First Draw	Tap	Room 104	<1	12/17/2018	
55.	17191	First Draw	Bubbler	Room 103	<1	12/17/2018	
56.	17192	First Draw	Tap	Room 103	<1	12/17/2018	Used by staff member this morning
57.	17193	First Draw	Bubbler	Across from Room 102	9	12/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
58.	17194	First Draw	Bubbler	Room 101	<1	12/17/2018	Used by students this morning
59.	17195	First Draw	Tap	Room 101	<1	12/17/2018	Used by students this morning
60.	17196	First Draw	Bubbler	Room 102	<1	12/17/2018	Used by students this morning
61.	17197	First Draw	Tap	Room 102	1	12/17/2018	Used by students this morning
62.	17198	First Draw	Tap	Library	9	12/17/2018	
63.	17199	First Draw	Tap	Kitchen	<1	12/17/2018	Left Compartment of 2 compartment used this morning
64.	17200	First Draw	Tap	Kitchen	<1	12/17/2018	Right compartment of two compartment sink used this morning
65.	17201	First Draw	Bubbler	Outside Cafeteria	<1	12/17/2018	
66.	17202	First Draw	Tap	Staff Lounge	1	12/17/2018	Used this morning by staff members
67.	17203	First Draw	Bubbler	Nurses Office	<1	12/17/2018	
68.	17204	First Draw	Tap	Nurses Office	1	12/17/2018	